

Missouri Department of Natural Resources



NOTIFICATION OF PERMIT REMOVAL

Date removed: August 1, 2021

Facility Name: East Highway 42 Business Park WWTF

Permit Number: MO-0128520

County: Miller

Facility Description: Non-POTW

Septic Tank / Recirculating Sand Filter / UV disinfection / sludge removed by contract hauler

Design Flow: 900 gallons per day.

Actual Flow: 700 gallons per day.

Reason for removal: The Department has terminated Permit # MO-0128520. This facility is now operating under Missouri State Operating Permit # MO-GD00550. The Master General Permit template can be found on the Department's website at:

<https://dnr.mo.gov/env/wpp/permits/issued/docs/GD00000.pdf>.

The applicable table for this facility is **Table E-1** found on Page 9 of 15. This facility is subject to the **Losing Stream** limits for *E. coli*.

If you have any questions about this permit please contact James VeVerka at (573)-522-5960 or by email at james.veverka@dnr.mo.gov.